

CHARACTERIZATION AND KINETIC  
STUDY OF ACTIVATED SLUDGE PROCESS  
IN PALM OIL MILL EFFLUENT (POME)  
TREATMENT

WUN WEE LONG

DOCTOR OF PHILOSOPHY

UNIVERSITI MALAYSIA PAHANG



### **SUPERVISOR'S DECLARATION**

We hereby declare that we have checked this thesis and, in our opinion, this thesis is adequate in terms of scope and quality for the award of the degree of Doctor of Philosophy (Chemical Engineering).

---

(Supervisor's Signature)

Full Name : TS DR.CHUA @ YEO GEK KEE

Position : ASSOCIATE PROFESSOR

Date :

---

(Co-supervisor's Signature)

Full Name : IR DR. CHIN SIM YEE

Position : ASSOCIATE PROFESSOR

Date :

---

(Co-supervisor's Signature)

Full Name : IR DR. NORAZWINA BINTI ZAINOL

Position : ASSOCIATE PROFESSOR

Date :



### **STUDENT'S DECLARATION**

I hereby declare that the work in this thesis is based on my original work except for quotations and citations which have been duly acknowledged. I also declare that it has not been previously or concurrently submitted for any other degree at Universiti Malaysia Pahang or any other institutions.

---

(Student's Signature)

Full Name : WUN WEE LONG

ID Number : PKC12003

Date :

CHARACTERIZATION AND KINETIC STUDY OF ACTIVATED SLUDGE  
PROCESS IN PALM OIL MILL EFFLUENT (POME)  
TREATMENT

WUN WEE LONG

Thesis submitted in fulfillment of the requirements  
for the award of the degree of  
Doctor of Philosophy

Faculty of Chemical and Process Engineering Technology  
UNIVERSITI MALAYSIA PAHANG

FEBRUARY 2020

## **ACKNOWLEDGEMENTS**

Firstly, I would like to express my sincere gratitude to my main supervisor, Dr. Chua @Yeo Gek Kee for her continuous support, patient, motivation and immense knowledge of my Ph.D study and related research. Beside my main supervisor, I also would like to thank to my co-supervisor, Dr. Chin Sim Yee and Dr. Norazwina binti Zainol for their insightful comments and guidance that helped me in all the time of research and writing of this thesis.

Also, thanks to I-Chem Solution Sdn Bhd management for their financial support and help rendered throughout my studies.

Last but not the least, I would like to express my heartfelt appreciation and gratitude to my wife, Tan Hui Ling and my daughters Wun Jing Woei and Wun Qing Er for their love, patient, understanding and encouragement that supported me through the whole study.

## ABSTRAK

Sejak beberapa dekad yang lalu, effluen kilang kelapa sawit (*POME*) merupakan salah satu isu utama alam sekitar di negara kita. Disebabkan piawai pelepasan yang ketat, banyak kilang kelapa sawit tidak dapat mematuhi piawai yang tertakluk dalam undang-undang alam sekitar. Oleh itu, sistem penggilapan rawatan *POME* telah dikembangkan dan dilaksanakan untuk meningkatkan prestasi proses rawatan biologi selepas rawatan sistem kolam. Walaupun demikian, proses rawatan biologi masih tidak dapat mencapai piawai pelepasan yang ditetapkan mungkin disebabkan reka bentuk sistem rawatan *POME* yang tidak sesuai. Bagi mencari punca kegagalan rawatan *POME* dalam pematuhan piawai pelepasan yang tertakluk dalam undang-undang, ciri-ciri *POME* and kajian kinetik rawatan *POME* telah dijalankan untuk memperolehi maklumat yang sesuai dalam rekaan bentuk sistem rawatan *POME*. Dalam kajian ini, penentuan komposisi fizikal telah dijalankan melalui proses pengeringan dan penyalan, manakala analisis penagihan saiz zarah (*PSD*) dijalankan melalui proses penapisan dengan menggunakan kertas turas saiz liang yang berbeza seperti 2  $\mu\text{m}$ , 5  $\mu\text{m}$ , 10  $\mu\text{m}$ , 20  $\mu\text{m}$ , 50  $\mu\text{m}$  and 100  $\mu\text{m}$ . Daripada keputusan kajian ini, sebanyak 46% pepejal tetap keseluruhan (*TFS*) didapati terkandung dalam pepejal keseluruhan (*TS*) dan sebanyak 63% pepejal keseluruhan terdiri daripada zarah-zarah pepejal dengan saiz 20-50  $\mu\text{m}$  dan 50-100  $\mu\text{m}$ . Selain itu, komposisi kimia utama dalam *POME* adalah keperluan oksigen biokimia (*BOD*) dan keperluan oksigen kimia (*COD*). Oleh itu, keperluan oksigen biokimia muktamad (*L<sub>0</sub>*) telah diramalkan melalui kaedah kajian kinetik *BOD* seperti *Least Square Method*, *Fujimoto Method*, *Thomas Graphical Method*, *Log Different Method* and *Method of Moment* dengan menggunakan keputusan *BOD* 7-hari anaerobik terawat *POME*. Manakala, penentuan pecahan *COD* anaerobik terawat *POME* seperti keperluan oksigen kimia bioterurai (*bcOD*) dan keperluan oksigen kimia bioterurai mudah larut (*srbCOD*) juga telah dijalankan serentak dengan kajian kinetik proses enapcemar teraktif dalam rawatan *POME*. Daripada kajian tersebut, didapati *L<sub>0</sub>*, *bcOD* dan *srbCOD* masing-masing dalam kepekatan 1,139 mg/L, 1,235 mg/L and 719 mg/L. Bagi menyiasat kesan-kesan keadaan operasi dalam kajian rawatan *POME* dengan menggunakan enapcemar teraktif, keadaan operasi seperti *pH* awal *POME*, masa pengekalan hidraulik (*HRT*), kadar muatan organik (*OLR*), pepejal terampai mudah meruap dalam campuran keras (*MLVSS*), masa pengekalan pepejal (*SRT*) dan kepekatan gula sebagai sumber karbon luaran telah dipilih dalam kajian ini. Kecekapan enapcemar teraktif dalam rawatan anaerobik terawat *POME* telah dinilai di bawah keadaan aerobik berdasarkan nisbah makanan dan mikroorganisma (*F/M ratio*) dalam 0.3 kg *BOD*/kg *MLVSS*/hari dan didapati keadaan operasi terbaik masing-masing adalah pada nilai  $6.5 \pm 0.1$ , 48 jam, 0.31 g *BOD<sub>3</sub>*/L.hari,  $2000 \pm 200$  mg/L, 10 hari and 50 mg/L dengan kecekapan penyingkiran *COD* dan *BOD* masing-masing sehingga 62 - 68% dan 60 - 65%. Dengan menggunakan nilai ciri-ciri *POME* dan keadaan operasi optimum, kajian kinetik rawatan *POME* dijalankan untuk memperolehi parameter kinetik. Dalam kajian ini, parameter kinetik bagi asas *COD* dan *BOD* telah didapati, di mana pekali hasil maksimum (*Y*), pekali pereputan dalam (*k<sub>d</sub>*), kadar penggunaan substrat spesifik maksimum (*k*) dan pemalar-halaju-separuh (*K<sub>s</sub>*) yang didapati pada nilai masing-masing 0.2369 mg *VSS*/mg *COD*, 0.1060 hari<sup>-1</sup>, 2.2717 hari<sup>-1</sup> and 758.7705 mg/L bagi asas *COD*, manakala nilai parameter kinetik untuk asas *BOD* masing-masing ialah 0.6718 mg *VSS*/mg *BOD<sub>3</sub>*, 0.0658 hari<sup>-1</sup>, 1.4136 hari<sup>-1</sup> and 556.1526 mg/L. Akhirnya, nilai-nilai yang diperolehi digunakan dalam mereka sistem rawatan *POME* dan membuat perbandingan dengan sistem rawatan *POME* yang direka dengan merujuk kepada nilai-nilai piawai yang dicadangkan oleh Jabatan Alam Sekitar yang diperolehi daripada loji rawatan air kumbahan.

## ABSTRACT

Due to the more stringent discharge standard of the environmental regulation, many palm oil mills are struggled to meet the compliance. Thus, the polishing treatment plant for palm oil mill effluent (POME) discharge are developed and implemented to enhance the biological treatment process after the conventional ponding system. Nevertheless, the biological treatment process yet to achieve the required discharge standard due to the inappropriate system design. Thus, characterization of POME and kinetic study of POME treatment was conducted to obtain the appropriate information for the POME treatment system design. In this study, physical composition determination was carried out through the drying and ignition process of anaerobic treated POME sample for solids contents analysis and particle size distribution (PSD) analysis was conducted via filtration process by using different pore size of filter paper (namely 2  $\mu\text{m}$ , 5  $\mu\text{m}$ , 10  $\mu\text{m}$ , 20  $\mu\text{m}$ , 50  $\mu\text{m}$  and 100  $\mu\text{m}$ ). There was about 46% of total fixed solids (TFS) had been found in total solids (TS) of POME and 63% of TS was contributed by solids particle with particle size of 20-50  $\mu\text{m}$  and 50-100  $\mu\text{m}$ . Besides, major contribution of chemical constituent in POME were biochemical oxygen demand (BOD) and chemical oxygen demand (COD). Hence, ultimate biochemical oxygen demand ( $L_0$ ) was estimated through BOD kinetic study methods, namely Least Square Method, Fujimoto Method, Thomas Graphical Method, Log Different Method and Method of Moment after conducting the 7-days BOD testing of anaerobic treated POME sample. While COD fractional of POME, namely biodegradable COD (bCOD) and soluble readily biodegradable (srbcOD) were determined concurrent with the kinetic study of activated sludge process in POME treatment. From the study, uBOD, bCOD and srbcOD was found at 1,139 mg/L, 1,235 mg/L and 719 mg/L, respectively. In order to investigate the effect of operating conditions on POME treatment using activated sludge, the selected operating conditions in this study were initial pH, hydraulic retention time (HRT), organic loading rate (OLR), initial mixed liquor volatile suspended solids (MLVSS), solid retention time (SRT), and molasses concentration added as a carbon source. The efficiency of activated sludge was evaluated by treating the anaerobic treated POME under aerobic conditions based on the Food to Microorganism (F/M) ratio of 0.3 kg BOD/kg MLVSS.day. The best operating condition for initial pH, HRT, OLR, initial MLVSS, SRT, and molasses concentration were found to be  $6.5 \pm 0.1$ , 48 hours, 0.31 g BOD<sub>3</sub>/L.day,  $2000 \pm 200$  mg/L, 10 days and 50 mg/L, respectively at the removal of chemical oxygen demand (COD) and biochemical oxygen demand (BOD) in POME ranging from 62 - 68% and 60 – 65% respectively. By using the result of characterization and optimum operating condition of POME treatment, kinetic study of POME treatment by activated sludge system were carried out to obtain the kinetic parameters for the POME treatment. From this kinetic study, the kinetic parameters for COD and BOD basis had been determined for maximum yields coefficient ( $Y$ ), endogenous decay coefficient ( $k_d$ ), maximum specific substrate utilization rate ( $k$ ) and half-velocity constant ( $K_s$ ) at 0.2369 mg VSS/mg COD, 0.1060 day<sup>-1</sup>, 2.2717 day<sup>-1</sup> and 758.7705 mg/L for COD basis whilst the kinetic parameters value for BOD basis were 0.6718 mg VSS/mg BOD<sub>3</sub>, 0.0658 day<sup>-1</sup>, 1.4136 day<sup>-1</sup> and 556.1526 mg/L, respectively. These kinetics parameters were important in designing the POME treatment system that is able to meet the standard as the design using DOE default value has been shown to under-design and failure to meet the required standard.

## **TABLE OF CONTENT**

<b>DECLARATION</b>	
<b>TITLE PAGE</b>	
<b>ACKNOWLEDGEMENTS</b>	<b>ii</b>
<b>ABSTRAK</b>	<b>iii</b>
<b>ABSTRACT</b>	<b>iv</b>
<b>TABLE OF CONTENT</b>	<b>v</b>
<b>LIST OF TABLES</b>	<b>ix</b>
<b>LIST OF FIGURES</b>	<b>x</b>
<b>LIST OF SYMBOLS</b>	<b>xiii</b>
<b>LIST OF ABBREVIATIONS</b>	<b>xvi</b>
<b>LIST OF APPENDICES</b>	<b>xviii</b>
<b>CHAPTER 1 INTRODUCTION</b>	<b>1</b>
1.1 Introduction	1
1.2 Problem Statement	2
1.3 Objectives of Study	3
1.4 Scope of Study	4
1.5 Significant of Study	5
<b>CHAPTER 2 LITERATURE REVIEW</b>	<b>7</b>
2.1 Introduction	7
2.2 Palm Oil Industry	7
2.2.1 History of Palm Oil in Malaysia	8
2.2.2 Supply and Demand for Palm Oil and Its Related Issues	8
2.2.3 Production of Palm Oil	10
2.2.4 Waste Generated from Palm Oil Production	11
2.2.5 Characteristic and Regulation on POME	11
2.3 Treatment Technology for POME	16
2.3.1 Conventional Method	17



2.3.2	Advance Treatment of POME	18
2.3.3	Current Issues in POME Treatment	20
2.4	Activated Sludge Process	21
2.4.1	Principles of Activated Sludge Treatment	22
2.4.2	Factors Affecting Activated Sludge	23
2.5	Kinetic Study of BOD	27
2.5.1	Least Square Method	29
2.5.2	Fujimoto Method	30
2.5.3	Thomas Graphical Method	31
2.5.4	Log Different Method	31
2.5.5	Method of Moment	32
2.6	Fractional Studies of Chemical Oxygen Demand (COD)	32
2.7	Kinetic Study of Activated Sludge Process	35
2.8	Design Calculation of Wastewater Treatment Plant	40
<b>CHAPTER 3 MATERIALS AND METHOD</b>		<b>42</b>
3.1	Introduction	42
3.2	Characteristic of Anaerobic Treated POME	42
3.2.1	Physical Composition	43
3.2.2	Chemical Composition	45
3.2.3	Other Measurements	47
3.3	Characterization of Activated Sludge	48
3.4	POME Treatment by Activated Sludge Process	49
3.4.1	Acclimatization of Activated Sludge in POME	49
3.4.2	Effect of Operating Parameters on POME Treatment by Activated Sludge Process	50
3.5	BOD Kinetic Study of POME	53
3.5.1	BOD Kinetic Parameters Estimation	53
3.5.2	Evaluation of Different Kinetic Study Methods	55
3.6	Chemical Oxygen Demand (COD) Fractional Studies of POME	56
3.6.1	Determination of Biodegradable Chemical Oxygen Demand (bCOD)	56
3.6.2	Determination of Soluble Readily Biodegradable Chemical Oxygen Demand (srbCOD) and Soluble Nonbiodegradable Chemical Oxygen	

	Demand (snbCOD)	58
3.6.3	Determination of Particulate Slowly Biodegradable Chemical Oxygen Demand (psbCOD) and Particulate Nonbiodegradable Chemical Oxygen Demand (pnbCOD)	59
3.7	Kinetic Study of Activated Sludge Process in POME Treatment	59
3.8	Design Calculation of POME Treatment System	61
<b>CHAPTER 4 RESULTS AND DISCUSSION</b>		<b>62</b>
4.1	Characterization of Anaerobic Treated POME	62
4.1.1	Physical Composition	62
4.1.2	Chemical Composition	66
4.2	Effect of Operating Parameters on POME Treatment by Activated Sludge Process	68
4.2.1	Effect of pH	68
4.2.2	Effect of Hydraulic Retention Time (HRT)	71
4.2.3	Effect of Organic Loading Rate (OLR)	73
4.2.4	Effect of Mixed Liquor Volatile Suspended Solid (MLVSS)	75
4.2.5	Effect of Solid Retention Time (SRT)	77
4.2.6	Effect of External Carbon Source	79
4.3	BOD Kinetic Study of POME	81
4.3.1	Least Square Method	82
4.3.2	Fujimoto Method	83
4.3.3	Thomas Graphical Method	83
4.3.4	Log Different Method	84
4.3.5	Method of Moment	85
4.3.6	Evaluation of BOD Kinetic Study Methods	87
4.4	Chemical Oxygen Demand (COD) Fractional Studies of POME	90
4.4.1	Determination of Biodegradable Chemical Oxygen Demand (bCOD)	90
4.4.2	Determination of Soluble Readily Biodegradable COD (srbCOD) and Soluble Nonbiodegradable COD (snbCOD)	91
4.4.3	Determination of Particulate Slowly Biodegradable COD (psbCOD) and Particulate Nonbiodegradable COD (pnbCOD)	92
4.5	Kinetic Study of Activated Sludge Process in POME Treatment	94

4.6	Design Calculation of POME Treatment Plant	97
<b>CHAPTER 5 CONCLUSIONS AND RECOMMENDATIONS</b>		<b>103</b>
5.1	Conclusions	103
5.2	Recommendations	104
<b>REFERENCES</b>		<b>105</b>
<b>PUBLICATIONS</b>		<b>140</b>

## LIST OF TABLES

Table 2.1	Summary of supply and demand for palm oil in 2017 and 2018	9
Table 2.2	Palm oil production in Malaysian Oil Palm Industry in 2017 and 2018	11
Table 2.3	Characteristic of raw POME from other studies	12
Table 2.4	Characteristic of anaerobic treated POME from other studies	13
Table 2.5	Categorization of particles in different types of particles size	15
Table 2.6	POME advance treatment methods from other studies	18
Table 3.1	Analyses used in the project and their corresponding reagents	45
Table 3.2	Sample volume required in BOD measurement	46
Table 3.3	Parameters monitored for difference activated sludge sample and supernatant during acclimatization periods	50
Table 3.4	Range of operating parameters studied in POME treatment	50
Table 4.1	BOD result for three samples of POME during 7-days incubation	81
Table 4.2	Computation table for $L_0$ and $k$ determination by using least square methods	82
Table 4.3	Computation table for BOD ( $y$ ) and $yt$ for BOD 7 days	87
Table 4.4	Summary of BOD kinetic parameters for POME	87
Table 4.5	Sum of absolute differences between the observed BOD and estimated BOD for different kinetic study methods	89
Table 4.6	Summary of BOD kinetic parameters for other industry	90
Table 4.7	Performance data for fractional studies of bCOD of POME	91
Table 4.8	Performance data for fractional studies of srbCOD and snbCOD of POME	92
Table 4.9	Calculated data for fractional studies of psbCOD and pnbCOD of POME	92
Table 4.10	Specific growth rate, specific substrate utilization rate, reciprocal substrate utilization rate and reciprocal substrate concentration on BOD <sub>3</sub> basis at different solid retention time for anaerobic treated POME	94
Table 4.11	Specific growth rate, specific substrate utilization rate, reciprocal substrate utilization rate and reciprocal substrate concentration on COD basis at different solid retention time for anaerobic treated POME	95

Table 4.12	Summary of kinetic parameters for the POME treatment by activated sludge process	97
------------	---	----

## LIST OF FIGURES

Figure 1.1	Objective of study with description of target objective	4
Figure 2.1	Export of palm oil product by destination in 2017 and 2018	10
Figure 2.2	Conventional ponding treatment system of POME	17
Figure 2.3	Schematic flow diagram of activated sludge process	22
Figure 2.4	Fractionation of COD in wastewater	33
Figure 2.5	Schematic diagram of the activated sludge process in a batch system	35
Figure 3.1	Schematic diagram of aeration tank for activated sludge process in POME treatment	56
Figure 4.1	Scheme of fractionation of solid content in anaerobic treated POME sample	64
Figure 4.2	Solid particle fractionation of anaerobic treated POME sample	65
Figure 4.3	Effect of initial pH on the pH after treatment and specific oxygen uptake rate of POME with operating condition: HRT = 48 hours, SRT = 7 days, MLVSS = $2,000 \pm 200$ mg/L, OLR = 0.31 g BOD <sub>3</sub> /L.day, molasses concentration = 20 mg/L	70
Figure 4.4	Effect of initial pH of POME on MLVSS:MLSS ratio and BOD <sub>3</sub> and COD reduction of POME with operating condition: HRT = 48 hours, SRT = 7 days, MLVSS = $2,000 \pm 200$ mg/L, OLR = 0.31 g BOD <sub>3</sub> /L.day, molasses concentration = 20 mg/L	71
Figure 4.5	Effect of HRT of POME on pH after treatment and specific oxygen uptake rate of POME with operating condition: initial pH of the POME = $6.5 \pm 0.1$ , SRT = 7 days, MLVSS = $2,000 \pm 200$ mg/L, OLR = 0.31 g BOD <sub>3</sub> /L.day, molasses concentration = 20 mg/L	72
Figure 4.6	Effect of HRT of POME on MLVSS:MLSS ratio and BOD <sub>3</sub> and COD reduction of POME with operating condition: initial pH of the POME = $6.5 \pm 0.1$ , SRT = 7 days, MLVSS = $2,000 \pm 200$ mg/L, OLR = 0.31 g BOD <sub>3</sub> /L.day, molasses concentration = 20 mg/L	73
Figure 4.7	Effect of OLR of POME on pH after treatment and specific oxygen uptake rate with operating condition: the initial pH = $6.5 \pm 0.1$ , HRT = 48 h, SRT = 7 days, MLVSS = $2,000 \pm 200$ mg/L, molasses concentration = 20 mg/L	74

Figure 4.8	Effect of OLR of POME on MLVSS:MLSS ratio and BOD <sub>3</sub> and COD reduction of POME with operating condition: the initial pH = $6.5 \pm 0.1$ , HRT = 48 h, SRT = 7 days, MLVSS = $2,000 \pm 200$ mg/L, molasses concentration = 20 mg/L	75
Figure 4.9	Effect of initial MLVSS of POME on pH after treatment and specific oxygen uptake rate with operating condition: the initial pH = $6.5 \pm 0.1$ , HRT = 48 h, OLR of 0.31 g BOD <sub>3</sub> /L.day, SRT = 7 days, molasses concentration = 20 mg/L	76
Figure 4.10	Effect of initial MLVSS of POME on MLVSS:MLSS ratio and BOD <sub>3</sub> and COD reduction with operating condition: the initial pH = $6.5 \pm 0.1$ , HRT = 48 h, OLR of 0.31 g BOD <sub>3</sub> /L.day, SRT = 7 days, molasses concentration = 20 mg/L	77
Figure 4.11	Effect of SRT of POME on pH after treatment and specific oxygen uptake rate of POME with operating condition: the initial pH = $6.5 \pm 0.1$ , HRT = 48 h, OLR of 0.31 g BOD <sub>3</sub> /L.day, MLVSS of $2,000 \pm 200$ mg/L, molasses concentration = 20 mg/L	78
Figure 4.12	Effect of SRT of POME on MLVSS:MLSS ratio and BOD <sub>3</sub> and COD reduction of POME with operating condition: the initial pH = $6.5 \pm 0.1$ , HRT = 48 h, OLR of 0.31 g BOD <sub>3</sub> /L.day, MLVSS of $2,000 \pm 200$ mg/L, molasses concentration = 20 mg/L	79
Figure 4.13	Effect of molasses as external carbon source concentration on pH after treatment and specific oxygen uptake rate of POME with operating condition: initial pH = $6.50 \pm 0.1$ , MLVSS = $2000 \pm 200$ mg/L, SRT = 10 days, HRT = 48 h, OLR = 0.31 g BOD <sub>3</sub> /L.day	80
Figure 4.14	Effect of molasses as external carbon source concentration On MLVSS:MLSS ratio and BOD <sub>3</sub> and COD reduction with operating condition: initial pH = $6.50 \pm 0.1$ , MLVSS = $2000 \pm 200$ mg/L, SRT = 10 days, HRT = 48 h, OLR = 0.31 g BOD <sub>3</sub> /L.day	81
Figure 4.15	Plot of BOD <sub>t+1</sub> versus BOD <sub>t</sub> and plot of the straight line with a slope of 1	83
Figure 4.16	Plot of $(t/y)^{1/3}$ as a function of time, $t$ (days)	84

Figure 4.17	Plot of $\log (dy/dt)$ versus time, $t$ (days)	85
Figure 4.18	Moore's diagram for BOD – 7 days	86
Figure 4.19	Plot of Observed BOD ( $y_o$ ) versus Estimated BOD ( $y_e$ ) value for different kinetic study methods	88
Figure 4.20	Mean concentration value of COD fractional for anaerobic treated POME	93
Figure 4.21	Plot of specific growth rate versus substrate utilization rate for maximum yields coefficient ( $Y$ ) and endogenous decay coefficient ( $k_d$ ) determination by using BOD <sub>3</sub> and COD result	96
Figure 4.22	Plot of reciprocal substrate utilization versus reciprocal effluent for maximum specific substrate utilization rate ( $k$ ) and half-velocity constant ( $K_s$ ) determination by using BOD <sub>3</sub> and COD result	97
Figure 4.23	Comparison of biological aeration tank volume design calculation based on BOD and COD basis in this study with DOE design criteria	100
Figure 4.24	Comparison of hydraulic retention time for biological aeration tank volume design calculation based on BOD and COD basis in this study with DOE design criteria	101
Figure 4.25	Comparison of F/M ratio for biological aeration tank volume design calculation based on BOD and COD basis in this study with DOE design criteria	102



## LIST OF SYMBOLS

$f_b$	Biodegradable fraction of VSS
$k$	Maximum specific substrate utilization rate ( $\text{day}^{-1}$ )
$k_d$	Endogenous decay coefficient ( $\text{day}^{-1}$ )
$K_s$	Half-velocity constant (mg/L of BOD) or (mg/L of COD)
$k_l$	Reaction rate constant (1/day)
$L_0$	Ultimate carbonaceous BOD (mg/L)
$L_r$	BOD remaining after time, $t$ (mg/L)
$m$	Number of data point minus one
$n$	No of days of incubation for the serial BOD test
$Q_i$	Flowrate of influent (L/day)
$Q_e$	Flowrate of effluent (L/day) or ( $Q_i - Q_w$ )
$Q_w$	Flowrate of wasted sludge (L/day)
$r_g$	Net rate of biomass production (mg VSS/L.day)
$r_{su}$	substrate utilization rate (mg/L.day)
$S_e$	Soluble substrate concentration in the effluent (mg/L)
$S_i$	Soluble substrate concentration in the influent (mg/L)
$S_{eBOD}$	Reciprocal substrate of BOD concentration (L/mg of BOD)
$S_{eCOD}$	Reciprocal substrate of COD concentration, (L/mg of COD)
$t$	Time (day)
$U$	Specific substrate utilization rate ( $\text{day}^{-1}$ )
$U_{BOD}$	Specific substrate utilization rate of BOD ( $\text{day}^{-1}$ )
$U_{COD}$	Specific substrate utilization rate of COD ( $\text{day}^{-1}$ )
$V_d$	Volume of aeration tank (L) calculated by using DOE formula
$V_p$	Volume of aeration tank (L) calculated by using industry formula
$V_r$	Volume of aeration tank (L)
$X$	Biomass concentration in the aeration tank (mg VSS/L)
$X_i$	Biomass concentration in the influent (mg VSS/L)
$X_e$	Biomass concentration in the effluent (mg VSS/L)
$X_w$	Biomass concentration in the wasted sludge (mg VSS /L)
$Y$	Yield coefficient (mg VSS/mg BOD) or (mg VSS/mg COD)
$y$	BOD exerted at time $t$ (mg/L)
$y'$	Rate of change of BOD (mg/L.day)

$y_e$	Estimated BOD (mg/L)
$y_o$	Observed BOD (mg/L)
$\theta$	Hydraulic retention time (day)
$\theta_c$	Solids retention time (days)
$1/\theta_c$	Specific growth rate (day <sup>-1</sup> )

## LIST OF ABBREVIATIONS

ABSR	Anaerobic bench scale reactor
ASBR	Anaerobic sequencing batch reactor
ASM1	Activated sludge model 1
ASM2	Activated sludge model 2
ASM2d	Activated sludge model 2d
ASM3	Activated sludge model 3
AN	Ammoniacal nitrogen
BOD	Biochemical oxygen demand
BOD <sub>3</sub>	Biochemical oxygen demand – 3 days, 30°C
BOD <sub>5</sub>	Biochemical oxygen demand – 5 days, 20°C
cBOD	Carbonaceous biochemical oxygen demand
nBOD	Nitrogenous biochemical oxygen demand
uBOD	Ultimate biochemical oxygen demand
COD	Chemical oxygen demand
bCOD	biodegradable chemical oxygen demand
nbCOD	Nonbiodegradable chemical oxygen demand
pnbCOD	Particulate nonbiodegradable COD
psbCOD	Particulate slowly biodegradable chemical oxygen demand
srbCOD	Soluble readily biodegradable chemical oxygen demand
snbCOD	Soluble nonbiodegradable chemical oxygen demand
tCOD	Total chemical oxygen demand
T <sub>b</sub> OD	Total biological demand
COD <sub>it</sub>	Initial total COD
COD <sub>is</sub>	Initial soluble COD
COD <sub>ism</sub>	Initial mixture soluble COD
COD <sub>itm</sub>	Initial mixture total COD
COD <sub>mb</sub>	Mixture biomass COD
COD <sub>ipm</sub>	Initial POME COD in mixture
COD <sub>fpm</sub>	Final POME COD in mixture
DO	Dissolved oxygen
DOE	Department of Environment
FFB	Fresh fruit bunch

FDS	Fixed dissolved solid
FSS	Fixed suspended solid
F/M Ratio	Food to Microorganism Ratio
HRT	Hydraulic retention time
IAAB	Integrated anaerobic-aerobic bioreactor
MLSS	Mixed liquor suspended solid
MLVSS	Mixed liquor volatile suspended solid
MPOB	Malaysian Palm Oil Board
MW	Molecular weight
O&G	Oil & grease
OLR	Organic loading rate
OUR	Oxygen uptake rate
PAH's	Polycyclic aromatic hydrocarbons
PAO's	Phosphorus accumulating organism
POME	Palm oil mill effluent
PSD	Particle size distribution
SBR	Sequencing batch reactor
SRT	Solid retention time
SS COD <sub>w</sub>	Suspended solid COD
SS COD <sub>im</sub>	Initial mixture suspended solid COD
SOUR	Specific oxygen uptake rate
TCMP	2-chloro-6-(trichloromethyl) pyridine
TDS	Total dissolved solid
TN	Total nitrogen
TS	Total solid
TFS	Total fixed solid
TSS	Total suspended solid
TVS	Total volatile solid
UASB	Upflow anaerobic sludge blanket
VDS	Volatile dissolve solid
VSS	Volatile suspended solid

## **LIST OF APPENDICES**

APPENDIX A	Raw data for characterization of anaerobic treated POME	121
APPENDIX B	Raw data for experiment of effect of initial pH on POME treatment	122
APPENDIX C	Raw data for experiment of effect of hydraulic retention time on POME treatment	124
APPENDIX D	Raw data for experiment of effect of organic loading rate on POME treatment	126
APPENDIX E	Raw data for experiment of effect of mixed liquor volatile Suspended solid on POME treatment	128
APPENDIX F	Raw data for experiment of effect of solid retention time on POME treatment	130
APPENDIX G	Raw data for experiment of effect of external carbon sources on POME treatment	132
APPENDIX H	Calculated data for BOD kinetic study of POME	134
APPENDIX I	Raw data for aeration tank volume of activated sludge system calculation	136

## REFERENCES

- Abdullah, A.Z., Ibrahim, M.H. and Kadir, M.O.A. (2004). Treatment of palm oil mill effluent (POME) supernatants using aerobic attached growth system: trickling filter as a case study. *Jurnal Teknologi*. 40(F), 77-90.
- Adeleke, A. O., Latiff, A. A. A. and Al-Gheethi, A. A. and Daud, Z. (2017). Optimization of operating parameters of novel composite adsorbent for organic pollutants removal from POME using response surface methodology. *Chemosphere*. 174, 232-242.
- Afroz, R. and Rahman, A. (2017). Health impact of river water pollution in Malaysia. *International Journal of Advanced and Applied Sciences*. 4(5), 78-85.
- Alhaji, A.M., Sanaullah, K., Lim, S.F., Khan, A., Hipolito, C.N., Abdullah, M.O., Bhawani, S.A. and Jamil, T. (2016). Photocatalytic treatment technology for palm oil mill effluent (POME) – A review. *Process Safety and Environmental Protection*. 102, 673-686.
- Ali, F. (2019, February 24). Reason for price fluctuation. *New Straits Time*. Retrieved from <http://www.nst.com.my>.
- Azmi, N.S. and Yunus, K.F.M. (2014). Wastewater treatment of palm oil mill effluent (POME) by ultrafiltration membrane separation technique coupled with adsorption treatment as pre-treatment. *Agriculture and Agricultural Science Procedia*. 2, 257-264.
- Clarke, J.S. (2019, March 18). How palm oil sparked a diplomatic row between Europe and Southeast Asia. *Unearthed*. Retrieved from <http://unearthed.greenpeace.org/2019/03/18/palm-oil-indonesia-malaysia-biofuels-eu>.
- Nambiappan, B., Ismail, A., Hashim, N., Ismail, N., Shahari, D.N., Idris, N. A. N., Omar, N., Salleh, K.M., Hassan, N. A. M. and Kushairi, A. (2018). Malaysia:100 years of resilient palm oil economic performance. *Journal of Oil Palm Research*. 30(1): 13-25.
- Bashir, M.J.K., Chong, J.W., Ng, C.A and Amr. S.S.A. (2017). Electro persulphate oxidation for polishing of biologically treated palm oil mill effluent (POME). *Journal of Environmental Management*. 193, 458-469.
- Basri, M.F., Yacob, S., Hassan, M.A., Shirai, Y., Wakisaka, M., Zakaria, M.R. and Phang, L.Y. (2010). Improved biogas production from palm oil mill effluent by a scaled-down anaerobic treatment process. *World Journal of Microbiology and Biotechnology*. 26, 505-514.
- Builtron, G., Gonzalez, A. and Lopez-marin, L.M. (1988). Biodegradation of phenolic compounds by an acclimated sludge and isolated bacteria. *Water Science and Tehcnology*. 37, 371-378.

- Chan, Y.J., Chong, M.F., Law, C.L. (2010a). Biological treatment of anaerobically digested palm oil mill effluent (POME) using a Lab-Scale Sequencing Batch Reactor (SBR). *Journal of Environmental Management*. 91, 1738 – 1746.
- Chan Y.J., Chong M.F., Law C.L. (2010b). Effects of temperature on aerobic treatment of anaerobically digested palm oil mill effluent (POME). *Industrial & Engineering Chemistry*. 49(15), 7093-7101.
- Chan, Y.J., Chong, M.F. and Law, C.L. (2011). Optimization on thermophilic aerobic treatment of anaerobically digested palm oil mill effluent (POME). *Biochemical Engineering Journal*. 55, 193-198.
- Chan, Y.J., Chong, M.F. and Law C.L. (2012). An integrated anaerobic-aerobic bioreactor (IAAB) for the treatment of palm oil mill effluent (POME): Start-up and steady state performance. *Process Biochemistry*. 47, 485-495.
- Chavez, A., Jimenez, B. and Maya, C. (2004). Particle size distribution as a useful tool for microbial detection. *Water Science & Technology*. 50(2), 179-186.
- Chibuoghu, O., Nweke, C.O., Nwabueze, R.N., Anyanwu, B.N., Chigbo, L.O. and Nwanyanwu, C.E. (2011). Effects of abattoir wastes on ammonium and nitrite consumptions in a tropical fresh water ecosystem. *Journal of Environmental Science and Technology*. 4(6), 590-600.
- Chin, K.K., Lee, S.W. and Mohammad, H.H. (1996). A study of palm oil mill effluent treatment using a pond system. *Water Science and Technology*. 34(11), 119–123.
- Chong, N.M., Luong, M. and Hwu, C.S. (2010). Biogenic substrate benefits activated sludge in acclimation to a xenobiotic. *Bioresource Technology*. 104, 181-186.
- Chou, K.W., Tan, S.W., Morad, N., Tow, T.T., Kadir, M.O.A. and Ismail, N. (2016). Aerobic post-treatment of different anaerobically digested palm oil mill effluent (POME). *International Journal of Environmental Science and Development*. 7(7), 511 – 515.
- Damayanti, A., Ujang, Z., Salim, M.R., Olsson, G. and Sulaiman, A.Z. (2010). Respirometric analysis of activated sludge models from palm oil mill effluent. *Bioresource Technology*. 101, 144-149.
- Davis, M.L. (2010). *Water and Wastewater Engineering – Design Principles and Practice (Professional Edition)*. McGraw-Hill, USA.
- Department of Environment Malaysia (DOE), (2010a). *Guidance Document on the Design and Operation of Industrial Effluent Treatment Systems, Specified in Regulation 5, Environmental Quality (Industrial Effluent) Regulation 2009*. 2<sup>nd</sup> Edition. Department of Environment Malaysia.

- Department of Environment Malaysia (DOE). (2010b). *Guidance Document on the Performance Monitoring of Industrial Effluent Treatment Systems, Specified in Regulation 9(a), Environmental Quality (Industrial Effluent) Regulation 2009*. 3<sup>rd</sup> Edition. Department of Environment Malaysia.
- Department of Environment (DOE). (2015). Draft Environmental Quality (Prescribed Premises) (Crude Palm Oil Mill) Regulation. *Federal Government Gazette*.
- Descoins, N., Deleris, S., Lestienne, R. Trouve, E. and Marechal, F. (2012). Energy efficiency in wastewater treatments plants: Optimization of activated sludge process couples with anaerobic digestion. *Energy*. 41(1), 153-164.
- Dionisi, D. and Rasheed, A.A. (2018). Maximisation of the organic load rate and minimisation of oxygen consumption in aerobic biological wastewater treatment processes by manipulation of the hydraulic and solids residence time. *Journal of Water Process Engineering*. 22, 138-146.
- Droste, R.L. (1997). *Theory and Practice of Waste and Wastewater Treatment*. John Wiley & Sons, Inc. USA.
- Durai, G., and Rajasimman, M. (2011). Biological treatment of tannery wastewater – a review. *Journal of Environmental Science and Technology*. 4(1), 1-17.
- Ekama, G.A., Marais, G.v.R., Siebritz, I.P., Pitman, A.R., Keay, G.F.P., Buchan, L., Gerber, A. and Smollen, M. (1984). Theory, design and operation of nutrient removal activated sludge process. Water Research Commission. WRC Report No.TT16/84.
- El-Shorbagy, W., Arwani, A. and Droste, R.L. (2011). Optimal sizing of activated sludge process with ASM3. *International Journal of Civil & Environmental Engineering*. 11(1), 19-33.
- El-Shorbagy., Radif, N.N. and Droste, R.L. (2013). Optimization of A(2)O BNR processes using ASM and EAWAG Bio-P models: model performance. *Water Environment Research*. 85(12), 2271-2284.
- Evans, A.E., Mateo-Sagasta, J., Qadir, M., Boelee, E. and Ipolito, A. (2018). *Environmental Sustainability*. 36, 20-27.
- Eze, V.C., Owunna, N. D. and Avoaja, D.A. (2013). Microbiological and Physicochemical Characteristics of Soil Receiving Palm Oil Mill Effluent in Umuahia, Abia State, Nigeria. *Journal of Natural Sciences Research*. 3(7).
- Fulazzaky, M.A., Nuid, M. and Muda, K. (2017). Mass transfer kinetics of biosorption of nitrogenous matter from palm oil mill effluent by aerobic granules in sequencing batch reactor. *Environ Technol*. 13, 1-11.
- Garcia-Mesa, J.J., Poyatos, J.M., Delgado, F. and Hontoria, E. 2010. The influence of biofilm treatment systems on particle size distribution in three wastewater treatment plant. *Water Air Soil Pollution*. 212, 37-49.



- Garcia-Mesa, J.J., Poyatos, J.M., Delgado-Ramos, F., Munio, M.M., Osorio, F. and Hontoria, E. (2010). Water quality characterization in real biofilm wastewater treatment systems by particle size distribution. *Bioresource Technology*. 101, 8038-8045.
- Ghangrekar M.M. (n.d.) Wastewater Management Course. NPTEL IIT Kharagpur Web Course.
- Gobi, K., Mashitah, M.D., Vadivelu, V.M., (2011). Development and utilization of aerobic granules for the palm oil mill (POM) wastewater treatment. *Chemicals Engineering Journal*.174, 213-220.
- Goswami, S. and Mazumder, D. (2015). Kinetic behavior of the activated sludge process used for treating composite chrome tannery wastewater. *Polish Journal of Environmental Studies*. 24(6), 2405 – 2409.
- Gerardi, M.H. (2006). Wastewater Bacteria. John Wiley & Sons, Inc. United States of America.
- Grady, C.P.L., Daigger, G.T. and Lim, H.C. (1999). Biological Wastewater Treatment (Second Edition, Revised and Expanded). Marcel Dekker, Inc. New York, USA.
- Gray N.F. (2004). *Biological of Wastewater Treatment*. Imperial College Press.
- Haider, H. and Ali, W. (2010). Effect of wastewater treatment on bio-kinetics of dissolved oxygen in River Ravi. *Pakistan Journal of Engineering and Applied Sciences*. 6, 42-51.
- Haruna, H. and Nor-Anuar.A. (2014). Development and Utilization of Aerobic Granules for Soy Sauce Wastewater Treatment: Optimization by Response Surface Methodology. *Jurnal Teknologi*. 69(5), 31-37.
- Henze, M., Gujer, W., Mino, T. and Loosdrecht, M.V. (2000). Activated Sludge Models ASM1, ASM2, ASM2d and ASM3. IWA Scientific and Technical Report. IWA Publishing, London, UK.
- Hiser, L, L., and Busch, A.W. (1964). An 8-hour biological demand test using mass culture aeration and COD. *Journal Water Pollution Control Federation*. 36, 505-516.
- Ho, C.C., Tan, Y.K. and Wang C.W. (1984). The distribution of chemical constituents between the soluble and the particulate fractions of palm oil mill effluent and its significance on its utilization/treatment. *Agricultural Wastes*. 11(1), 61-71.
- Hojjat, M., Mustapha, S.B. and Salleh, M.A.M. (2009). Optimization of POME anaerobic pond. *European Journal of Scientific Research*. 32(4), 455-459.
- Hreiz, R., Latifi, M.A., and Roche, N. (2015a). Optimal design and operation of activated sludge process: State-of-the art. *Chemical Engineering Journal*. 281, 900-920.

- Hreiz, R., Roche, N., Benyahia, B. and Latifi, M.A. (2015b). Multi-objective optimal control of small-size wastewater treatment plants. *Chemical Engineering Research and Design*. 102, 345-353.
- Huan, K.L. (1987). Trials on long-term effects of application of POME on soil properties, oil palm nutrition and yields. In: Proceedings of the International Oil Palm, Palm Oil Conferences (eds.) Dr. B. Hj. Abdul Halim, Hassan Chew Poh Soon, B.J. Woond, Dr. E. PushParajah (eds.) 2, 575-598.
- Huo, S., Xi, B., Yu, H., Qin, Y., Zan, F. and Zhang, J. (2013). Characteristics and transformations of dissolved organic nitrogen in municipal biological nitrogen removal wastewater treatment plants. *Environmental Research Letters*. 8(044005). doi:10.1088/1748-9326/8/4/044005.
- Huzira, N. M., Azizb, M. M. A., Ismail, S. B., Mahmooda, N. A. N., Umord, N. A. and Muhammada, S. A. F. S. (2019). Optimization of coagulation-flocculation process for the palm oil mill effluent treatment by using rice husk ash. *Industrial Crops & Products*. 39, 111482.
- Iskandar, M.J., Azizah Baharum, A., Anuar, F.H. and Othaman, R. (2018). Palm oil industry in South East Asia and the effluent treatment technology—A review. *Environmental Technology & Innovation*. 9, 169–185.
- Karahan, O., Dogruel, S., Dulekgurgen, E. and Orhon, D. (2008). COD fractionation of tannery wastewaters-particle size distribution, biodegradability and modelling. *Water Research*. 42(4-5), 1083-1092.
- Karia, G.L. and Christian, R.A. (2013). *Wastewater Treatment – Concepts and Design Approach (Second Edition)*. PHI Learning Private Limited. Delhi, India.
- Kathiravale, S. and Ripin, A. (1997). Treatment of palm oil mill effluent using evaporation and adsorption techniques. Regional Symposium on Chemical Engineering.
- Krishnamoorthy, S., Premalatha, M. and Vijayasekaran, M. (2017). Characterization of distillery wastewater - an approach to retrofit existing effluent treatment plant operation with phycoremediation. *Journal of Cleaner Production*. 148, 735-750.
- Levine, A.D., Tchobanoglous, G. and Asono, T. (1991). Size distributions of particulate contaminants in wastewater and their impact on treatability. *Water Research*. 25(8), 911-922.
- Liew, W.L., Kassim, M.A., Muda, K., Loh, S.K. and Affam, A.C. (2015). Conventional methods and emerging wastewater polishing technologies for palm oil mill effluent treatment: A review. *Journal of Environmental Management*. 149, 222-235.
- Lim, J.X. and Vadivelu, V.M. (2014). Treatment of agro based industrial wastewater in sequencing batch reactor: performance evaluation and growth kinetics of aerobic biomass. *Journal of Environmental Management*. 146, 271-225.

- Limkhuansuwan V., Chaiprasert P. (2010). Decolorization of molasses melanoidins& Palm Oil Mill Effluent phenolic compound by fermentative lactic acid bacteria. *Journal of Environmental Science*. 22(8), 1209-1217.
- Liyanage, C.P. and Yamada, K. (2017). Impact of population growth on the water quality of natural water bodies. *Sustainability*. 9, 1405.
- Loh, S.K., Lai, M.E., Ngatiman, M., Lim, W.S., Choo, Y.M., Zhang, Z.J. and Salimon, J. (2013). Zero discharge treatment technology of palm oil mill effluent. *Journal of Oil Palm Research*. 25(3), 273-281.
- Loh, S.K., Nasrin, A.B., Azri, S.M., Adela, B.N., Muzzammil, N., Jay, T.D., Eleanor, R.A.S., Lim, W.S., Choo, Y.M. and Kaltschmitt, M. (2017). First report on Malaysia's experience and development in biogas capture and utilization from palm oil mill effluent under the Economic Transformation Programme: Current and future perspective. *Renewable and Sustainable Energy Reviews*. 74, 1257-1274.
- Ma, A.N. and Ong, A.S.H. (1985). Pollution Control in Palm Oil Mills in Malaysia. Palm Oil Research Institute of Malaysia (PORIM). *Journal of the American Oil Chemist's Society (JAOCs)*. 63(2).
- Ma, A.N. (1999). Environmental Management for the palm oil industry. *Palm Oil Development*. 30, 1-10.
- Mamais D., Jenkins D., and Pitt P. (1993). A rapid physical-chemical method for the determination of readily biodegradable soluble COD in municipal wastewater. *Water Research*. 27(1), 195-197.
- Malakahmad, A., Lahin, F.A. and Yee W. (2014). Biodegradation of high – strength palm oil mill effluent (POME) through anaerobes partitioning in an integrated baffled reactor inoculated with anaerobic pond sludge. *Water Air Soil Pollution*. 225, 1883.
- Malaysia. (2017). *Environmental Quality Act, 1974 (Act 127)*, Regulation, Rules & Orders. Environmental Quality (Prescribed Premises) (Crude Palm Oil) Regulation 1977.
- Mardani, S., Mirbagheri, A., Amin, M.M. and Ghasemian. (2011). Determination of biokinetic coefficients for activated sludge processes on municipal wastewater. *Iranian Journal of Environmental Health Science & Engineering*. 8(1), 25-34.
- Marquet, R. Mietton-Peuchot, M. and Wheatly, A.D. (1999). Characterization of trickling filter effluent by particle size distribution and high-performance size exclusion Chromatography. *Water Research*. 33(6), 1415-1424.
- Mayo, A.W. and Abbas, M. (2014). Removal mechanism of nitrogen in waste stabilization ponds. *Physics and Chemistry of the Earth*. 72-75, 77-83.
- Ming, K.K., and Chandromohan, D. (2002). Malaysian palm oil industry at crossroad and its future direction. *Oil Palm Industry Economic Journal*. 2(2), 10-15.

- Mohammed, R.R. and Chong, M.F. (2014). Treatment and decolorization of biologically treated palm oil mill effluent (POME) using banana peel as novel biosorbent. *Journal of Environmental Management*. 132, 237-249.
- Mohammed, R.R., Ketabchi, M.R. and McKay, G. (2014). Combined magnetic field and adsorption process for treatment of biologically treated palm oil mill effluent (POME). *Chemical Engineering Journal*. 243, 31-42.
- MPOB, Malaysian Palm Oil Board. (2018a). Retrieved from <http://bepi.mpob.gov.my/index.php/en/statistics/export/192-export-2018/869-monthly-export-of-oil-palm-products-2018.html>.
- MPOB, Malaysian Palm Oil Board. (2018b). Retrieved from <http://bepi.mpob.gov.my/index.php/en/statistics/price/monthly.html>.
- MPOB, Malaysian Palm Oil Board. (2018c). Retrieved from <http://bepi.mpob.gov.my/index.php/en/statistics/export/192-export-2018/867-export-of-palm-oil-to-major-destinations-2018.html>.
- MPOB, Malaysian Palm Oil Board. (2018d). Retrieved from <http://bepi.mpob.gov.my/index.php/en/statistics/sectoral-status/190-sectoral-status-2018/861-ffb-processed-by-mill-2018.html>.
- MPOB, Malaysian Palm Oil Board. (2018e). Retrieved from <http://bepi.mpob.gov.my/index.php/en/statistics/production/186-production-2018/850-production-of-crude-oil-palm-2018.html>.
- MPOB, Malaysian Palm Oil Board. (2018f). Retrieved from <http://bepi.mpob.gov.my/index.php/en/statistics/production/186-production-2018/848-production-of-crude-palm-kernel-oil-2018.html>.
- MPOB, Malaysian Palm Oil Board. (2018g). Retrieved from <http://bepi.mpob.gov.my/index.php/en/statistics/sectoral-status/190-sectoral-status-2018/864-number-a-capacities-of-palm-oil-sectors-2018.html>.
- Muda, K., Aris, A., Salim, M.R., Ibrahim, Z., Loosdrecht, M.C.M.V., Ahmad, A. and Nawahwi, M.Z. (2011). The effect of hydraulic retention time on granular sludge biomass in treating textile wastewater. *Water Research*. 45, 4711- 4721.
- Mullis, M.K., and Schroeder, E.D. (1971). A rapid biochemical oxygen demand test suitable for operational control. *Journal of Water Pollution Control Federation*. 43(2), 209-215.
- Mutamim, N.S.A., Noor, Z.Z., Hassan, M.A.A. and Olsson, G. (2012). Application of membrane bioreactor technology in treating high strength industrial wastewater: a performance review. *Desalination*. 305, 1-11.

- Najafpour, G., Yieng, H.A., Younesi, H. and Zinatizadeh, A. (2005). Effect of organic loading on performance of rotating biological contactors using palm oil mill effluents. *Process Biochemistry*. 40, 2879-2884.
- Najafpour, G., Sadeghpour, M. and Lorestani, A.Z. (2007). Determination of kinetic parameters in activated sludge process for domestic wastewater treatment plant. *Chemical Industry and Chemical Engineering Quarterly*. 13(4), 211-215.
- Neoh C.H. et al. (2012). Optimization of decolorization of Palm Oil Mill Effluent (POME) by growing cultures of *Aspergillus fumigatus* using response surface methodology. *Environmental Science Pollution Research*. 20(5), 2912-23. doi: 10.1007/s11356-012-1193-5.
- Nguyen, L.H. and Chong, N.M. (2015). Energy profiles of activated sludge degradation of xenobiotic compound. *Chemical Engineering Transactions*. 54, 1555 – 1560.
- NSTOnline (May, 2017). Celebrating 100 years of Malaysian palm oil (Part 1). *New Straits Time*. Retrieved from <https://www.nst.com.my/news/nation/2017/05/240770/celebrating-100-years-malaysian-palm-oil-part-1>.
- Economic Co-operation and Development (OECD) (2019). *Economic Outlook for Southeast Asia, China and India 2019*. OECD Publishing. Retrieved from <http://dx.doi.org/10.1787/saeo-2019-en>.
- Ohimain E.I., Izah S.C., Jenakumo N. (2013). Physiochemical and microbial screening of palm oil mill effluents for amylase production. *Greener Journal of Biological Sciences*. 3(8), 307 – 318.
- Okwute, L. O. and Isu, N. R. (2007). The Environmental Impact of Palm Oil Mill Effluent (POME) on some physicochemical parameters and total aerobic bioload of soil at a dump site in Anyigba, Kogi State, Nigeria. *African Journal of Agricultural Research*, 2(12), 656 - 662.
- Onyia, C.O., Uyub, A.M., Akunna, J.C., Norulaini, N.A. and Omar, A.K.M. (2001). Increasing the fertilizer value of palm oil mill sludge: bioaugmentation in nitrification. *Water Science Technology*. 44(10), 157-162.
- Pace, C.M. (1995). Measurement of high molecular weight polycyclic aromatic hydrocarbons in soils by particle beam high performance liquid chromatography-mass spectrometry. *Journal of American Society for Mass Spectrometry*. 6, 597-607.
- Paixao S.M., Baeta-Hall L., Anselmo A.M. (2000). Evaluation of two commercial microbial inocula as seed in a 5-day biochemical oxygen demand test. *Water Environment Research Washington, D.C.* 72(3).

- Pan, S., Tay, J.H., He, Y.X. and Tay, S.T.L. (2004). The effect of hydraulic retention time on the stability of aerobically grown microbial granules. *Letters in Applied microbiological*. 38, 158:163.
- Park, J.K., Wang, J. and Novotny, G. (1997). Wastewater characterization for evaluation of biological phosphorus removal. Research Report (Wisconsin Department of Natural Resources). 174.
- Peavy, H.S., Rowe, D.R. and Tchobanoglous, G. (1985). *Environmental Engineering (International Edition)*. McGraw-Hills Book Co., Singapore.
- Perez, M., Romero, L.I. and Sales, D. (2001). Organic matter degradation kinetics in anaerobic thermophilic fluidized bed bioreactor. *Anaerobe*. 7(1): 25-35.
- Poh, P.E. and Chong, M.F. (2014). Upflow anaerobic sludge blanket-hollow centered packed bed (UASB-HCPB) reactor for thermophilic palm oil mill effluent (POME) treatment. *Biomass and Bioenergy*. 67, 231-242.
- Qasim, S.R. (1999). *Wastewater Treatment Plants – Planning, Design, and Operation (Second Edition)*. CRC Press LLC. New York, USA.
- Ramalho R.S. (1977). *Introduction to Wastewater Treatment Processes*. Academic Press Inc.
- Rahman, A.K.A., Abdullah, R., Balu, N. and Shariff, F.M. (2013). The Impact of La Nina and El Nino events on crude palm oil prices: An econometric analysis. *Oil Palm Industry Economic Journal*. 13(2), 38-51.
- Rasdy, N.F.A., Sanagi, M.M., Ibrahim, W.A.W. and Naim, A.A. (2008). Determination of polycyclic aromatic hydrocarbon in palm oil mill effluent by Soxhlet extraction and gas chromatography-flame ionization detection. *The Malaysian Journal of Analytical Sciences*. 12(1).
- Rifin, A. (2010). Export competitiveness of Indonesia's palm oil product. *Trends in Agriculture Economic*. 3(1):1-8.
- Sadoff, C.M., Hall, J.W., Grey, D., Aerts, J.C.J.H., Ait-Kadi, M., Brown, C., Cox, A., Dadson, S., Garrick, D., Kelman, J., McCornick, P., Ringler, C., Rosegrant, M., Whittington, D., Wilberg, D. (2015). *Securing Water, Sustainable Growth: Report of the GWP/OECD Task Force on Water Security and Sustainable Growth*. University of Oxford, UK.
- Samudro, G. and Mangkoedihardjo, S. (2010). Review on BOD, COD and BOD/COD ratio: A triangle zone for toxic, biodegradable and stable levels. *International Journal of Academic Research*. 2(4), 235-239.
- Schuyler, R.G. (2010). *Activate Sludge Process Control Troubleshooting Chart (Second Edition)*. Tetra Tech, Inc. Colorado, USA.

- Sheikh, R.E., Gouda, A.A., Salem, A. and Hendy, I. (2016). Analysis and characterization of wastewater nitrogen components for using in wastewater modeling and simulation. *International Journal of Advanced Research in Chemical Science*. 3(5), 28-36.
- Shun D.L. (2014). *Water and Wastewater Calculations Manual*. The McGraw-Hills Education.
- Singh, B. (2004). *Determination of BOD kinetic parameters and evaluation of alternate methods*. Master Thesis. Thapar Institute of Engineering & Technology, India.
- Song, Y.J., Xie, Y.B. and Yudianto, D. (2012). Extended activated sludge model no.1 (ASM1) for simulating biodegradation process using bacterial technology. *Water Science and Engineering*. 5(3), 278-290.
- Sophonsiri, C. and Morgenroth, E. (2004). Chemical composition associated with different particle size fractions in municipal, industrial, and agricultural wastewaters. *Chemosphere*. 55: 691-703.
- Tabassum, S., Zhang, Y.J. and Zhang, Z.J. (2015). An integrated method for palm oil mill effluent (POME) treatment for achieving zero liquid discharge – A pilot study. *Journal of Cleaner Production*. 95, 148-155.
- Taha, M.R. and Ibrahim, A.H. (2014). COD removal from anaerobically treated palm oil mill effluent (AT-POME) via aerated heterogenous Fenton process: Optimization study. *Journal of Water Process Engineering*. 1, 8-16.
- Tchobanoglous, G., Burton, F.L. and Stensel, H.D. (2004). *Wastewater Engineering Treatment and Reuse (Fourth Edition)*. Metcalf & Eddy Inc., McGraw-Hills Education, New York, USA.
- Teng, T.T., Wong, Y.S., Ong, S.A., Norhashimah, M. and Rafatullah, M. (2013). Start-up operation of anaerobic degradation process for palm oil mill effluent in anaerobic bench scale reactor (ABSB). *Procedia Environmental Sciences*. 18, 442-450.
- Tintometer Gmbh. (May, 2015). The importance of Biochemical Oxygen Demand (BOD) in the water analysis sector. Retrieved from <http://www.envirotech-online.com>.
- Tran, N.H., Hgo, H.H., Urase, T. and Gin, K.Y.H. (2015). A critical review on characterization strategies of organic matter for wastewater and water treatment processes. *Bioresource Technology*. 193, 532-533.
- Vesilind, P.A., Pierce, J.J. and Weiner, R.F. (1998). *Environmental Pollution and Control*, Butterworth-Heinemann, Boston, Mass, USA.
- Vijayaraghavan, K., Ahmad, D., Ezani Bin Abdul Aziz, M. (2007). Aerobic treatment of palm oil mill effluent. *Journal of Environmental Management*. 82, 24-31.
- Wang, M., and Chen, Y. (2018). Generation and characterization of DOM in wastewater treatment processes. *Chemosphere*. 201, 96-109.

- Wang, S., Zhang, X., Wang, Z.W., Li, X. and Ma, J. (2014). In-depth characterization of secondary effluents from a municipal wastewater treatment plant located in northern China for advance treatment. *Water Sci. Technol.* 69, 1482-1488.
- Water Environment Federation (WEF). (2008). *Operation of Municipal Wastewater Treatment Plants, Manual of Practice No.11, Volume II: Liquid Processes (Six Edition)*. Water Environment Federation, McGraw-Hills, New York, USA.
- Water Environment Federation (WEF). (2010). *Design of Municipal Wastewater Treatment Plants (Fifth Edition). Volume 2: Liquid Treatment Processes*. Water Environment Federation, McGraw-Hills, Alexandria, Virginia, USA.
- Wentzel M.C., Mbewe A., Lakay M.T., Ekama G.A. (1999). Batch test of characterization of the carbonaceous materials in municipal wastewater. *Water SA*. 25(3).
- Wu, T.Y., Mohammad, A.W., Jahim, J.M. and Anuar, N. (2010). Pollution control technologies for the treatment of palm oil mill effluent (POME) through end-of-pipe processes. *Journal of Environmental Management*. 91, 1467-1490.
- Wu, W., Wu, P., Yang, F., Sun, D.L., Zhang, D.X. and Zhou, Y.K. (2018). Assessment of heavy metal pollution and human health risks in urban soils around an electronic manufacturing facility. *Science of the Total Environment*. 630, 53-61.
- Yacob, S., Hassan, M.A., Shirai, Y., Wakisaka, M. and Subahs, S. (2005). Baseline study of methane emission from open digesting tanks of palm oil mill effluent treatment. *Chemosphere*, 59, 1575-1581.
- Yamashita, T. and Ikemoto, R.Y. (2014). Nitrogen and phosphorus removal from wastewater treatment plant effluent via bacterial sulfate reduction in an anoxic bioreactor packed with wood and iron. *International Journal of Environmental Research and Public Health*. 11, 9835 – 9853.
- Yu, H., Song, Y., Liu, R., Pan, H., Xiang, L. and Qian F. (2014). Identifying changes in dissolved organic matter content and characteristics by fluorescence spectroscopy coupled with self-organizing map and classification and regression tree analysis during wastewater treatment. *Chemosphere*. 113, 79-86.
- Zainal, N.H., Jalani, N.F., Mamat, R. and Astimar, A.A. (2017). A review on the development of palm oil mill effluent (POME) final discharge polishing treatments. *Journal of Oil Palm Research*. 29(4), 528-540.
- Zakariah, Z. (2019, March 4). Malaysia to export US\$891M palm oil to China. *New Straits Time*. Retrieved from <http://www.nst.com.my>.
- Zharim, A.Y., Rachel, F.M. Menaka, S. Su, S.Y., Melvin, F. and Chan, E.S. (2009). Decolourisation of anaerobic palm oil mill effluent via activated sludge-granular activated Carbon. *World Applied Science Journal* 5 (Special Issue of Environment).126-129.



Zielinska, M., Bernat K., Cydzik-Kwiatkowska, A. and Wojnowska-Baryla, I. (2012).  
Respirometric Activity of Activated Sludge in Sequencing Batch Reactor  
Depending on Substrate and Dissolved Oxygen Concentration. *Environmental  
Protection Engineering*. 38(2).